

ΣΥΝΤΕΛΕΣΤΗΣ ΔΙΟΡΘΩΣΗΣ C								
Ονομαστική πίεση τροφοδοσίας (mbarg)	ΒΙΠΕ ΛΑΡΙΣΑΣ	ΒΟΛΟΣ	ΘΕΣΣΑΛΟΝΙΚΗ	ΚΑΡΔΙΤΣΑ	ΚΟΚΚΙΝΑ	ΛΑΡΙΣΑ	ΤΡΙΚΑΛΑ	ΦΑΡΣΑΛΑ
<25	0,99714	1,00370	0,99988	1,01476	0,99824	1,00710	1,01452	1,01373
50	1,02617	1,03292	1,02898	1,04431	1,02730	1,03642	1,04406	1,04324
70	1,04552	1,05241	1,04839	1,06401	1,04668	1,05597	1,06375	1,06292
100	1,07456	1,08163	1,07750	1,09356	1,07574	1,08530	1,09330	1,09244
250	1,21979	1,22783	1,22314	1,24139	1,22114	1,23200	1,24109	1,24012
300	1,26822	1,27659	1,27170	1,29069	1,26962	1,28092	1,29038	1,28937
500	1,46208	1,47174	1,46610	1,48802	1,46370	1,47674	1,48766	1,48650
800	1,75322	1,76482	1,75804	1,78440	1,75516	1,77085	1,78397	1,78257
1000	1,94755	1,96046	1,95291	1,98224	1,94971	1,96716	1,98176	1,98021
2000	2,92205	2,94158	2,93014	2,97454	2,92531	2,95173	2,97381	2,97146